



No Lesen : FL000028

Licence No :

## SIJIL BARANGAN TERSENARAI

### *Product Listing Certificate*



SIRIM

SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

TROCELLEN S. E. A. SDN. BHD.  
LOT 2213, KG BATU 9 KEBUN BARU  
JALAN KASAWARI  
TELOK PANGLIMA GARANG  
42500 TELOK PANGLIMA GARANG  
SELANGOR, MALAYSIA

Sijil untuk menggunakan Tanda Barangan Tersenarai  
*a certificate to use the Listed Product Mark on*

**POLYETHYLENE FOAM LAMINATED WITH ALUMINIUM FOIL**

**Please refer to detail in the SCHEDULE**

sebagai mematuhi keperluan  
*as complying with*

**BS 476 : PART 6 : 1989 + A1 : 2009**

**BS 476 : PART 7 : 1997**

**Mohd Azanuddin bin Salleh**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.  
(No. Syarikat 410334-X)  
1, Persiaran Dato' Menteri  
Seksyen 2, Peti Surat 7035  
40700 Shah Alam  
Selangor Darul Ehsan  
MALAYSIA.

Tel : 60-3-55446400  
Faks : 60-3-55446466

<http://www.sirim.my>

<http://www.malaysiancertified.com.my>

**Tarikh Mula Pensijilan : 16 March 2015**

*Certified Since*

**Sah Sehingga : 16 March 2021**

*Valid Until*

**Tarikh Dikeluarkan : 03 March 2020**

*Issue Date*

**No Siri : 053508**

*Serial No*

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.

*This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.*

## SCHEDULE

### TROCELLEN S. E. A. SDN. BHD.



Trade Mark : TROCELLEN PRO  
Model : 2506W3CF2 733 + ALU, 2508W3CF2 733 + ALU  
Rating : Foam Density: 25 kg/m<sup>3</sup>  
Fire Propagation Index: 9.9, 7.6  
Surface Spread of Flame: Class One  
Type : Polyethylene foam with facing material : Aluminium Foil  
Size : Nominal Thickness: 6 mm, 8 mm  
Test report no.: 2014FE0307, 2014FE0303, 2014FE0306, 2014FE0302

Trade Mark : TROCELLEN PRO  
Model : 2506W3CF4 733 + ALU-S, 2512W3CF4 733 + ALU-S, 2530W3CF4L 733 + ALU-S  
Rating : Foam Density: 25 kg/m<sup>3</sup>  
Fire Propagation Index: 5.6, 4.0, 7.7  
Surface Spread of Flame: CLASS ONE  
Type : Polyethylene foam with facing material : Aluminium Foil  
Size : Nominal Thickness: 6mm – 30mm  
Test report no.: 2016FE0108, 2016FE0109, 2016FE0107, 2016FE0105, 2016FE0253, 2016FE0254

Trade Mark : TROCELLEN PRO  
Model : 3305NF4 775 + ALU-S, 3310NF4 775 + ALU-S, 3312NF4 775 + ALU-S  
Rating : Foam Density: 33 kg/m<sup>3</sup>  
Fire Propagation Index: 6.9, 8.5, 5.9  
Surface Spread of Flame: CLASS ONE  
Type : Polyethylene foam with facing material : Aluminium Foil  
Size : Nominal Thickness: 5mm – 12mm  
Test report no.: 2016FE0102, 2016FE0103, 2016FE0100, 2016FE0101, 2016FE0252, 2016FE0099

## SCHEDULE

TROCELLEN S. E. A. SDN. BHD.



**SIRIM**

Trade Mark : TROCELLEN PRO  
Model : Trocellen Pro – AirPro Plus  
Rating : Foam Density: 25 kg/m<sup>3</sup>  
Fire Propagation Index: 6.6, 7.5, 9.8  
Surface Spread of Flame: CLASS ONE  
Type : Polyethylene foam with facing material : Aluminium Foil  
Size : Nominal Thickness: 6mm – 30mm  
Test report no.: 2018FE0590, 2018FE0591, 2018FE0675, 2018FE0676, 2019FE0499,  
2019FE0450

---

*End of page*

---